

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

MTS: UATYA25BBAY1*, UATYA25BFC2Y1*, UATYA25BFC3Y1*,

MTO: 25*...*,**

* = , 1, 2, 3, ..., 9

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008***

as amended,

S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

following the provisions of: BS EN 60204-1: 2018, BS EN 61000-6-3: 2021, BS EN 61000-6-2: 2019, BS EN 378-2: 2016, IEC 60335-2-40: 2018,

* as set out in <A> and judged positively by according to the **Certificate <C>**.

** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>) according to the **Certificate <G>**. Risk category <H>. Also refer to next page.

*** Daikin Europe N.V. is authorised to compile the Technical Construction File.

<A>	—
	—
<C>	—
<D>	—
<E>	Bureau Veritas Italia S.p.A. (NB1370)
<F>	H
<G>	—
<H>	II

2P522682-5C



Hiromitsu Iwasaki
Director
Ostend, 3rd of October 2022

DAIKIN EUROPE N.V.
Zandvoordestraat 300, B-8400 Oostende, Belgium



UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): **<K>** (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: **<L>** (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): **<M>** (°C)

Refrigerant: **<N>**

Setting of pressure safety device: **<P>** (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<K>	PS	43.3 bar
<L>	TSmin	-20 °C
<M>	TSmax	150 °C
<N>		R32
<P>		42 bar

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: **<Q>**

<Q> Bureau Veritas Italia S.p.A. Via Miramare 15, 20126 Milano (MI), Italy
