

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

EPRA14DAV3(7), EPRA16DAV3(7), EPRA18DAV3(7), EPRA14DAW1(7), EPRA16DAW1(7), EPRA18DAW1(7),

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016** as amended,
S.I. 2016/1101: Electrical Equipment (Safety) Regulations 2016
S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*

following the provisions of: BS EN 60335-2-40, BS EN 55014-1:2017 + A11: 2020, BS EN 55014-2: 2015, BS EN IEC 61000-3-2: 2019, BS EN 61000-3-3: 2013, BS EN 61000-3-11: 2000, BS EN 61000-3-12: 2011,

* as set out in <A> and judged positively by according to the **Certificate <C>**.

** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

<A>	DAIKIN.TCF.034C3/02-2022
	—
<C>	—
<D>	DAIKIN.TCFP.006
<E>	HPi-CEproof Ltd. (NB1521)
<F>	B+D
<G>	—
<H>	III

UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): **<K>** (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: **<L>** (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): **<M>** (°C)

Refrigerant: **<N>**

Setting of pressure safety device: **<P>** (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<K>	PS	56 bar
<L>	TSmin	-28 °C
<M>	TSmax	70 °C
<N>		R32
<P>		56 bar

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: **<Q>**

<Q> HPI-CEproof Ltd.
The Manor House
Howbery Business Park
Wallingford
OX10 8BA
United Kingdom

